


	AQUAVAS S.A. VASLUI SUCURSALA VASLUI			
	Str. Alecu Donici, nr. 23, Vaslui, Cod postal 730150, Romania NR. Inregistrare la Reg. Com.: J37/892/2007, CIF: RO-17988823, CUI: 2586122 Cont: RO59 RNCB 0259 0284 5277 0019, deschis la BCR Vaslui			

 Nr. 1296 din 29.03.2019


BULETIN ANALIZA
CALITATE APA POTABILA

Luna MARTIE 2019

Nr. crt.	Indicatorul	U.M.	Legea 458/2002	Intrare statie				Iesire Statie
				Solesti	Barlad	Puscasi	Amestec	
1.	pH	Unitati de pH	$\geq 6,5 \leq 9,5$	8,25		8,21	8,24	7,75
2.	Conductivitate	$\mu S/cm^{-1}$	< 2500	889,25		867,25	877	903,46
3.	Turbiditate	U.N.T.	≤ 5	15,94		33,53	19,57	2,33
4.	Oxidabilitate	mg. O ₂ / dm ³	≤ 5	5,57		6,29	5,71	3,90
5.	Aluminiu	$\mu g / dm^3$	200	17,73		15,30	14,28	140,85
6.	Amoniu - NH ₄ ⁺	mg / dm ³	0,50	0,137		0,047	0,068	0,018
7.	Nitriti - NO ₂ ⁻	mg / dm ³	0,50	0,027		0,034	0,028	0,004
8.	Nitrati - NO ₃ ⁻	mg / dm ³	50	0,35		1,62	0,38	0,40
9.	Cloruri	mg / dm ³	250	37,93		32,85	33,81	45,90
10.	Duritate totala	grade germane	> 5	22,28		21,31	21,49	22,29
11.	Nr. total de colonii la 36° C	U.F.C. / 1cm ³	NOMA	215		415	310	0
12.	Enterococi fecali	nr. / 100 cm ³	0	1		5	2	0
13.	Bacterii coliforme	nr. / 100 cm ³	0	1700		6975	2450	0
14.	Clostridium perfringens	nr. / 100 cm ³	0	33		180	45	0
15.	Nr. total de colonii la 22° C	U.F.C. / 1cm ³	NOMA	315		675	425	1

Sef laborator,
ing. Musat Oana

Musat