


→ MR. TEHLIC  
04.10.2017

	<b>AQUAVAS S.A. VASLUI</b> <b>SUCURSALA VASLUI</b> Str. Alecu D. Onici, nr. 23, Vaslui, Cod postal 730150, Romania NR. Inregistrare la Rog. Com. 33/692/2007, CIF RO-17986823, CUI 2506127 Cont. RO59 RNCD 0255 0284 5277 0019, Bancha de BCR Vaslui	TOV CERT ISO 9001	TOV PROF ISO 14001	TOV CERT ISO 18001
		TOV CERT ISO 9001	TOV PROF ISO 14001	TOV CERT ISO 18001

Nr. 3347 din 04.10.2017

S.C. AQUAVAS S.A. VASLUI  
 REGISTRATURA FAX  
 INTRARE NR. 925  
 IESIRE NR. 925  
 Ziua 04 luna 10 anul 2017

**BULETIN ANALIZA**  
**CALITATE APA POTABILA**

Luna SEPTEMBRIE 2017

Nr. crt.	Indicatorul	U.M.	Legea 458/2002	Intrare statie				Iesire Statie
				Solesti	Barlad	Puscasi	Amestec	
1.	pH	Unitati de pH	> 6,5-9,5	8,17				7,19
2.	Conductivitate	$\mu S/cm^3$	< 2500	689,27				716,97
3.	Turbiditate	U.N.T	< 5	41,58				3,21
4.	Oxidabilitate	mg. O <sub>2</sub> / dm <sup>3</sup>	< 5	12,63				5,83
5.	Aluminiu	$\mu g / dm^3$	200	11,22				120,2
6.	Amoniu - NH <sub>4</sub> <sup>+</sup>	mg / dm <sup>3</sup>	0,50	0,063				sld
7.	Nitriti - NO <sub>2</sub>	mg / dm <sup>3</sup>	0,50	0,020				sld
8.	Nitrati - NO <sub>3</sub>	mg / dm <sup>3</sup>	50	0,80				0,75
9.	Cloruri	mg / dm <sup>3</sup>	250	30,85				54,51
10.	Calciu	mg / dm <sup>3</sup>	-	59,2				59,2
11.	Duritate totala	grade germane	> 5	16,45				16,86
12.	Nr. total de colonii la 36 <sup>o</sup> C	U.F.C. / 1cm <sup>3</sup>	NOMA	> 300				0
13.	Enterococi fecali	nr. / 100 cm <sup>3</sup>	0	13				0
14.	Bacterii coliforme	nr. / 100 cm <sup>3</sup>	0	39750				0
15.	Clostridium perfringens	nr. / 100 cm <sup>3</sup>	0	4				0
16.	Nr. total de colonii la 22 <sup>o</sup> C	U.F.C. / 1cm <sup>3</sup>	NOMA	> 300				0

Sef laborator,  
 Ing. Musat Oana